



TEL: (352) 331-1976 132 NW 76th Drive, Gainesville, Florida 32607
TEL: (352) 414-4621 101 NE 1st Avenue, Ocala, Florida 34470
WWW.CHW-INC.COM

[planning](#).[surveying](#).[engineering](#).[construction](#).

FIELD ORDER NO. 3

To: Blake Fletcher
Project: Walnut Creek, Phase II
P.N.: 14-0059
From: Erin Hughes, EI
Date: August 7, 2015
CC: Josh Highlander, PE, CHW
Gene Arnold, R.E. Arnold
Subject: Overflow Discharge Revisions

Description of field order:

The purpose of this field order is to modify the pond and swale so that the berm of the pond closes around the swale at 170.7 feet. In addition, the cross drain piping and MES's are to be removed from the plans.

If the Contractor feels that a change order is warranted by the work described above, the Contractor shall submit an itemized proposal for the changes in the Contract Sum and Contract Time, prior to commencement of work. Within seven days of the date of this Field Order, the Contractor shall submit the itemized proposal or notify the Architect / Engineer in writing of the date on which the proposal is anticipated. If the proposal or notification of the anticipated proposal is not received within seven days, then it is inferred that the change has no material cost or time extension and the work is to be executed accordingly

1B TYPE P-7-T JUNC. BOX
TOP EL = MATCH EX. SIDEWALK
INV. EL = 163.95' N. ±
INV. EL = 163.95' S. ±
INV. EL = 164.5' N.E.

INSTALL ±30" 24" HDPE

CONST. 5' WIDE BERM TO ELEV. 170.7.
BERM TO CLOSE AT 170.7' AROUND SWALE

CENTER SIDEWALK BETWEEN TREES CLEAR BY HAND

DELETE CROSS DRAIN PIPING AND MES'S

CONSTRUCT OVERFLOW PATH. SEE SECTION "B" DWG. 33.

1A OVERFLOW STRUCTURE
TYPE C INLET
TOP EL = 169.5'
INV. EL = 165.5' S.
(LEAVE GRADE DOWN 3" AROUND INLET AT 169.25')


N.W. 31st Avenue
Glen Springs Road

N.W. 26th Street

SANITARY SEWER MANHOLE
TOP ELEVATION - 171.84'

STORM MANHOLE
TOP ELEVATION - 171.26"
INV. = 166.69 N. & W.

BENCH MARK
TOP OF CONCRETE MONUMENT
ELEVATION - 172.36'



PROJECT #14-0059
WALNUT CREEK PHASE II

DATE: 08/07/15 FIELD ORDER #3

JOSHUA A. HIGHLANDER

FL PE No. 72971



132 NW 76th Drive
Gainesville, Florida 32607
(352) 331-1976 / (352) 331-2476
www.chw-inc.com

est. 1988 FLORIDA
CA-5075